



An **AEP** Company

BOUNDLESS ENERGY™

## Pirkey Plant

### Notice of Statistically Significant Levels (SSLs) above the Groundwater Protection Standard (GWPS)

#### CCR Unit – East Bottom Ash Pond

As required by 40 CFR 257.95(g), this is a notification that on July 12, 2019 lithium and cobalt were detected at SSLs above the GWPSs. This notification is being placed in the operating record, as required by 40 CFR 257.105(h)(8).

BOUNDLESS ENERGY™