



An **AEP** Company

BOUNDLESS ENERGY™

## Northeastern Power Station

### Notice of Statistically Significant Levels (SSLs) above the Groundwater Protection Standard (GWPS)

#### CCR Unit – Bottom Ash Pond

As required by OAC 252:517-9-6 (g), this is a notification that on February 19, 2021 lithium and fluoride were detected at SSLs above the GWPS during the 2nd semi annual 2020 sampling event. This notification is being placed in the plant's operating record, as required by OAC 252:517-19-1(h)(8).

BOUNDLESS ENERGY™