

## Mountaineer Plant

### Notice of Statistically Significant Levels (SSLs) above the Groundwater Protection Standard (GWPS)

#### CCR Unit – Bottom Ash Pond

As required by 40 CFR 257.95(g) and 33 CSR1B, this is a notification that on March 14, 2024, arsenic, and lithium were detected at SSLs above the GWPSs. This notification is being placed in the operating record, as required by 40 CFR 257.105(h)(8) and 33 CSR1B. The CCR Unit remains in corrective action.