



An **AEP** Company

BOUNDLESS ENERGY™

Northeastern Power Station

Notice of Initiating an Assessment of Corrective Measures

CCR Unit – Bottom Ash Pond

As required by OAC 252:517-9-6(g)(5), this is a notification that an Assessment of Corrective Measures was initiated on July 8, 2019 for Northeastern Power Station's Bottom Ash Pond due to the statistically significant level detected above the established groundwater protection standard for lithium. This notification is being placed in the plant's operating record, as required by OAC 252:517-19-1(h)(9).

BOUNDLESS ENERGY™