



An **AEP** Company

BOUNDLESS ENERGY™

Northeastern Power Station

Notice of Statistically Significant Levels (SSLs) above the Groundwater Protection Standard (GWPS)

CCR Unit – Bottom Ash Pond

As required by OAC 252:517-9-6 (g), this is a notification that on April 18, 2022 lithium, barium, and fluoride were detected at SSLs above the GWPS during the 2nd semi-annual 2021 groundwater sampling event. This notification is being placed in the plant's operating record, as required by OAC 252:517-19-1(h)(8).

BOUNDLESS ENERGY™