



An **AEP** Company

BOUNDLESS ENERGY™

Pirkey Plant

Notice of Statistically Significant Levels (SSLs) above the Groundwater Protection Standard (GWPS)

CCR Unit - Landfill

As required by 40 CFR 257.95(g), this is a notification that on July 11, 2019 lithium and cobalt were detected at SSLs above the GWPSs. This notification is being placed in the plant's operating record, as required by 40 CFR 257.105(h)(8).

BOUNDLESS ENERGY™