

Clinch River Plant

Notice of Statistically Significant Levels (SSLs) above the Groundwater Protection Standard (GWPS)

CCR Unit – Pond 1

As required by 40 CFR 257.95(g), this is a notification that on February 22, 2024, barium, cobalt, lithium, and molybdenum were detected at SSLs above the GWPSs. This notification is being placed in the operating record, as required by 40 CFR 257.105(h)(8).